



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	8170-2180:0501
CATEGORY:	8170 - IGNITION-RESISTANT MATERIALS
LISTEE:	Plycem USA 396 W. Greens Rd., Suite 300, Houston, TX, 77067 Contact: Bower, Kelin (844)525-5872 Email: kbower@elementia.com
DESIGN:	<p>*Allura® and TerraPlank™ fiber cement board products 5/16" thick, available in the following profiles: Allura® and TerraPlank™ Lap Siding, Allura® and TerraPlank™ Vertical Panel, Allura® and TerraPlank™ Shake, Allura® Shake Select, and Allura® Soffit.</p> <p>Refer to manufacturer's installation instructions and product data sheets for additional detailed product description and construction.</p>
RATING:	<p>Tested in accordance with ASTM E84 with an additional 20 minutes.</p> <p>Class A</p> <p>Flame Spread Index: 0</p> <p>Smoke Developed Index: 5</p> <p>Max Flame Front: 0 feet</p>
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, rating, and SFM label.
APPROVAL:	*Listed as an ignition resistant material in accordance with Section 704A.3 of the 2022 California Building Code. Refer to listee's Installation Instruction Manual for details. Models complies with the applicable requirements in ASTM E84 with an additional 20-minute period.
NOTES:	*Formerly: 8160-2180:0501

10-08-24 MH

*Revised



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 10/21/2024

Listing Expires: 06/30/2025

Authorized By: **Michael Huang**, Program Coordinator
Fire Engineering & Investigations Division