CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No.:	8170-2180:0502
CATEGORY:	8170 - IGNITION-RESISTANT MATERIALS
LISTEE:	Plycem USA 396 W. Greens Rd., Suite 300, Houston, TX, 77067 Contact: Bower, Kelin 8445255872 Email: kbower@elementia.com
DESIGN:	Allura and TerraPlank fiber-cement exterior cladding in the following profiles: shake siding, non-vented soffits and ceilings. Material is fiber-cement and 1/4-inch thick. Refer to manufacturer's installation instructions and product data sheets.
RATING:	Tested in accordance with ASTM E84 with an additional 20-minute period Ignition-Resistant and Class A Flame Spread Index: 0 Smoke Developed Index: 0 Maximum Flame Front: 0 ft
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, rating and QAI label.
APPROVAL:	Listed as an ignition resistant material for exterior coverings in accordance with Section 704A.3 of the 2022 California Building Code. Refer to listee's Installation Instruction Manual for details. Models comply with the applicable requirements in ASTM E84 with an additional 20-minute period.
NOTES:	

8/5/2025 GA

This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

Date Issued: 06/26/2026

Listing Expires: 06/30/2027

Authorized By: **Michael Huang**, Program Coordinator
Fire Engineering & Investigations Division